

WESTCOAST NEW ZEALAND ENERGY- COMMUNICATION RESILIENCE ASSESSMENT FACTORING AF8 LIKELY TRAJECTORIES


*Presenters: Duncan Kaniaru, Farrukh Latif
Energy-Communication Resilience
Research Group*



ENGINEERING


DEPARTMENT OF ELECTRICAL,
COMPUTER, AND SOFTWARE ENGINEERING

Energy Communication: Resilience group



Project Milestones

NZ Electricity Distribution Network Resilience Assessment and Restoration Models following Major Natural Disturbance



Nov 2017 to May 2018



Hazard mapping to Infrastructure Impact

Apr 2018 to Mar 2019



Communication Infrastructure Provisions

Jun 2017 to June 2019






Simulation, Design and Testing for Micro-grid operation of West Coast

May 2018 to Sept 2019



Resilient energy-communication Utility Service Framework

Milestone 1-Hazard Mapping





Milestone 1-Methodology



Component Fragility Curves

OR


Component Fragility Assumption




Milestone 1 – Possible trajectories




Central Hypocenter



Southern Hypocenter




Northern Hypocenter




Empirical Southern Hypocenter


Milestone 1 – Examples of Possible Outcomes



CH MMI 9





NH MMI 9




CH MMI 8

Milestone 1: Agreed Scenario




Recap – NZ Electrical Power System



NEW ZEALAND'S ELECTRICITY GENERATION (12 months to Nov 2014)

GENERATION TYPE	PERCENTAGE
Hydro	59.6%
Geothermal	16.3%
Gas	15.8%
Wind	4.6%
Coal	3.0%
Wood	0.7%



Transmission Line Construction Voltage


- 350 kV
- 220 kV
- 110 kV
- ≤ 66 kV



Recap – Power System Variables

- Voltage: 415V, 11KV, 33KV, 66KV, 110KV, 220KV: Acceptable Limits 0.95-1.05
- Frequency: 50Hz: Acceptable Limits 48.5-51.5Hz

Frequency: Generation = Demand





<https://www.rs.tus.ac.jp/j.kondoh/english.html>

Islanding

- Islanding: Condition in which a section of the grid (transmission or distribution) is energized and operational, whilst disconnected from the main grid (transmission or distribution).

- Formation of islands
 - Blackstart** - Re-energization of components
 - Transitional** – Components remain energized after separation from the grid.

- Blackstart Islanding** is preferred in case of disasters as damage assessment is required to determine status of network components





Westpower: SouthWestland Network

Power Station	Power Capacity (MW)	Blackstart Capability
McKays Creek	1.1	No
Kaniere Forks	0.5	No
Amethyst	7.4	Yes
Wahapo	3.1	Yes
Fox	0.5	No

Zone Substations	Peak Demand (MW)
Hokitika*	19.576
Ross	0.500
Waitaha	0.350
Hari Hari	0.980
Wahapo	0.100
Whataroa	0.782
Franz Josef	2.212
Fox Glacier	1.016

* Load at Hokitika is inclusive of all the loads of the South Westland Network



LEGEND


- 110 kV
- 66 kV
- 33 kV
- 11 kV
- 6.6 kV
- 3.3 kV
- Transpower Owned
- Demarcation Point
- Power Station
- Open Tie
- GXP (KUM066)



ENGINEERING
DEPARTMENT OF ELECTRICAL,
COMPUTER, AND SOFTWARE ENGINEERING

Component Modelling


Generator Modelling




Transformer Modelling




Transmission Line Modelling



General Cable Construction 1kV ~ 35 kV, Copper / Al Conductor




Load Modelling




33 kV Network Energization: Voltage

- Sequential energization of zone substation transformers and overhead lines. Voltages are within safe limits
- Example: Energization of Franz Josef transformer





Franz Josef transformer energization





33 kV Network Energization: Frequency

- Frequency drop as a result of large transformer energization but within acceptable limits
- Example: Energization of Franz Josef transformer






Load pickup





Load pickup

- Different scenarios at the Hari Hari 11kV feeder .




Sequential Load Pickup

- Maximum load step: 0.5 MW
- Load composition: 75% - static, 25% - Motor





Transitioning to Islanding

- Island detection necessary mainly for safety and to enable the DER to change operating modes.
- Amethyst uses frequency (Active Power Mismatch) change for islanding detection.
- Voltage and voltage angle will be investigated.
- Amount of Load at Hokitika to be varied.





Transitioning to Islanding

Scenario 1: Hokitika Load – 9MW, 1.28 MVar





Transitioning to Islanding

Scenario 2: Hokitika Load – 4.5MW, 0.64 MVar




Transitioning to Islanding

Scenario 3: Hokitika Load – 0.99MW/0.14MVA_r



In summary


Westcoast Electricity Network Resilience




Earthquake scenarios:

- Central Hypocenter
- Northern Hypocenter
- Southern Hypocenter
- Empirical Southern Hypocenter



Hazard Mapping





Energy Communication: Resilience group



NZ Fixed Communication Infrastructure and Services




Method for Seismic Risk Analysis (SRA) and Hazard Mapping




Milestone 2: West Coast Case Study


Fragility Curves for Central Offices





AF8 Earthquake Hazard Scenarios





Chorus Central Offices (Assets)





CO Risk Quantification using Geo-Spatial Mapping (AF8 Central)



CO Risk Quantification using Geo-Spatial Mapping (AF8 Southern)



CO Risk Quantification using Geo-Spatial Mapping (AF8 Northern)



Milestone 2: Summary Results

AF8 Scenario	MMI	Minor(ds0)	Moderate(ds1)	Extensive(ds2)	Complete(ds3)	Affected Central Offices/Telco Infrastructure
Central Hypocenter	7	52%	14%	13%	0%	FJG,GC,HAS,INJ,KM,MIA,MKN,WMG
	8	86%	56%	21%	3%	AU,BTN,FXR,HK,MNA,NE,OTI,RN,RUN,WP,WAA
	9	95%	80%	43%	10%	DOB,GM,HRI,KUA,PAR,RS
AF8 Scenario	MMI	Minor(ds0)	Moderate(ds1)	Extensive(ds2)	Complete(ds3)	Affected Central Offices/Telco Infrastructure
Northern Hypocenter	6	7%	0%	0%	0%	GC,INJ,KM,MIA,MKN,WMG
	7	52%	14%	13%	0%	AU,BTN,DOB,GM,HK,KUA,MNA,NE,OTI,PAR,RN,RUN,WP
	8	86%	56%	21%	3%	FXR,FJG,HAS,HRI,RS,WAA
AF8 Scenario	MMI	Minor(ds0)	Moderate(ds1)	Extensive(ds2)	Complete(ds3)	Affected Central Offices/Telco Infrastructure
Southern Hypocenter	7	52%	14%	13%	0%	FJG,GC,KM,MIA,MKN,WMG
	8	86%	56%	21%	3%	AU,BTN,FXR,HK,HAS,INJ,MNA,NE,OTI,RN,RUN,WP,WAA
	9	95%	80%	43%	10%	DOB,GM,HRI,KUA,PAR,RS
AF8 Scenario	MMI	Minor(ds0)	Moderate(ds1)	Extensive(ds2)	Complete(ds3)	Affected Central Offices/Telco Infrastructure
Empirical Southren Hypocenter	5	4%	0%	0%	0%	GC,INJ,KM,MIA,MKN,WMG,WP
	6	7%	0%	0%	0%	AU,BTN,DOB,GM,MNA,NE,PAR,RN,RUN
	7	52%	14%	13%	0%	HK,KUA,OTI
	8	86%	56%	21%	3%	HAS,RS
	9	95%	80%	43%	10%	FXR,FJG,HRI,WAA

Westcoast Central Offices(CO) Resilience and Availability Quantification

AF8 Scenario	Number of CO impacted
Central Hypocenter MMI 7	8
Central Hypocenter MMI 8	19
Central Hypocenter MMI 9	25
Northern Hypocenter MMI 7	19
Northern Hypocenter MMI 8	25
Southern Hypocenter MMI 7	6
Southern Hypocenter MMI 8	19
Southern Hypocenter MMI 9	25
Empirical Southern Hypocenter MMI 7	19
Empirical Southern Hypocenter MMI 8	21
Empirical Southern Hypocenter MMI 9	25

unavailability for AF8 Scenarios


AF8 Scenario	Loss of CO in West Coast Network	Availability of CO in West Coast Network
Central Hypocenter MMI 7	0.47	2.13
Central Hypocenter MMI 8	3.17	0.32
Central Hypocenter MMI 9	Total Loss	0.00
Northern Hypocenter MMI 7	3.17	0.32
Northern Hypocenter MMI 8	Total Loss	0.00
Southern Hypocenter MMI 7	0.32	3.17
Southern Hypocenter MMI 8	3.17	0.32
Southern Hypocenter MMI 9	Total Loss	0.00
Empirical Southern Hypocenter MMI 7	3.17	0.32
Empirical Southern Hypocenter MMI 8	5.25	0.19
Empirical Southern Hypocenter MMI 9	Total Loss	0.00

Loss and Availability Quantification

Milestone 2: Conclusion

From the above analysis, hazard mapping is important to estimate the level of damage that can be caused by the specific disaster. The estimation can then be used to drive policy decisions with regards to network investments. The investments can either be in the form of assets robustness (which has been the common practice) or re-architecture the network topology to improve the end to end resilience of network thus services. **From West Coast Communication infrastructure resilience assessment, it can be noted that there is a higher risk of losing Grey Mouth (tier 2 central office) in case of Central and Southern Hypocenter MMI9 AF8 scenarios than the other two AF8 scenarios under study.**

NZ Electricity Distribution Network Resilience Assessment and Restoration Models following Major Natural Disturbance



NGĀ MIHI – ACKNOWLEDGEMENTS

This work is supported financially by the New Zealand Ministry of Business, Innovation and Employment under the 'Resilience to Nature's Challenges' (Infrastructure) National Science Challenge.

The 'NZ Electricity Distribution Network Resilience Assessment and Restoration Models following Major Natural Disturbance' project is a joint project led by the Power System Group from the Department of Electrical and Computer Engineering, University of Auckland. Westpower is the distribution utility under study.

This project will contribute to the resilience of the electrical infrastructure of West Coast New Zealand against different natural hazards with focus on the Alpine fault rupture. It aims to introduce appropriate resilience metrics, assess and improve the resilience of electrical infrastructure of the West Coast electrical distribution network.

Project supporters

Primary Funder

Co - Funder

In - Kind Support

Research lead

Research Partners

© 2019 The Authors

Published by Power Systems Group, Department of Electrical & Computer Engineering, Faculty of Engineering

University of Auckland, Auckland 1010, New Zealand

NGĀ MIHI – ACKNOWLEDGEMENTS

This work is supported financially by the New Zealand Ministry of Business, Innovation and Employment under the 'Resilience to Nature's Challenges' (Infrastructure) National Science Challenge. 'Resilience Assessment of Electricity and NZ Fixed Telecom following Major Earthquake' is a joint project led by the Power and Communication System Group from the Department of Electrical, Computer and Software Engineering, University of Auckland. Chorus is the UFB infrastructure company in the West Coast NZ.

This project will contribute to the resilience of the Electricity and Communication infrastructure of West Coast New Zealand against different natural hazards with focus on the Alpine fault rupture. It aims to introduce appropriate resilience metrics, assess and improve the resilience of Electrical and Communication infrastructure of the West Coast.

Project supporters

Primary Funder

Co - Funder

In - Kind Support

Research lead

Research Partners

DOCUMENTATION SUMMARY

This report presents collaborative work of members from the Power and Communication Systems Group of the University of Auckland for the project titled "Functionality Assessment of West Coast NZ Fixed Communication Infrastructure following Major Earthquake". The contributors to this report are Farrukh Latif, Andrew Austin and Nirmal Nair.

Document:

Functionality Assessment of West Coast NZ Fixed Communication Infrastructure following Major Earthquake

Prepared for:

Ministry of Business, Innovation and Employment, New Zealand

Consolidated by:

Farrukh Latif
 RNCEI Group, University of Auckland

Revision	Date	Submission	Reviewer's Feedback
1	June 2019	Communication Infrastructure Assessment Report	Initial Draft
2	July 2019	Communication Infrastructure Assessment Report	Andrew Austin
3	Aug 2019	Communication Infrastructure Assessment Report	Liam Wotherspoon

DOCUMENTATION SUMMARY

This report presents collaborative work of members from the Power Systems Group of the University of Auckland for the project titled "NZ Electricity Distribution Network Resilience Assessment and Restoration Models following Major Natural Disturbance". The contributors to this report are Duncan Kaniaru Maina, Samad Shirzadi Deh Kohneh, Safa Al-Sachit, Leo Yang Liu and Nirmal Nair.

Document:

NZ Electricity Distribution Network Resilience Assessment and Restoration Models following Major Natural Disturbance

Prepared for:

Ministry of Business, Innovation and Employment, New Zealand

Consolidated by:

Duncan Kaniaru Maina
 Samad Shirzadi Deh Kohneh
 Safa Al-Sachit
 Leo Yang Liu
 Power Systems Group, University of Auckland

Revision	Date	Submission	Reviewer	Reviewer's Feedback
1	September 2018	Milestone 1 Report	Daniel Blake (University of Canterbury)	Corrections on methodology explanation
2	July 2019	Milestone 3 Report	Rodger Griffiths (Westpower)	Corrections on network components descriptions



ENGINEERING
 DEPARTMENT OF ELECTRICAL AND COMPUTER ENGINEERING

POWER SYSTEMS GROUP

Tel: 64 9 923 9523

Fax: 64 9 373 7461



IEEE ISGT-ASIA 2017



CIGRE AUCKLAND 2017



EEA 2019




EEA 2018

CIGRE NZ FORUM 2019



AUPEC 2018



Appreciation

Electricity Distribution Resilience Framework through West Coast Alpine Fault Scenario

Nirmal Nair (PI), Andrew Austin (AI), Farrukh Latif (ME, Chorus), Samad Shirzadi (PhD), Duncan Maina (PhD), Yang Liu (Postdoc), Daniel Blake (Postdoc), Liam Wotherspoon (RNC DI, Lead)

RESILIENCE
TO NATURE'S
CHALLENGES

Kia manawaroa
– Ngā Ākina o
Te Ao Tūroa

National
SCIENCE
Challenges



ENGINEERING
DEPARTMENT OF ELECTRICAL,
COMPUTER, AND SOFTWARE ENGINEERING



QuakeCoRE
NZ Centre for Earthquake Resilience



Orion

C H ● R U S

WESTCOAST NEW ZEALAND ENERGY- COMMUNICATION RESILIENCE ASSESSMENT FACTORIZING AF8 LIKELY TRAJECTORIES

*Presenters: Duncan Kaniaru, Farrukh Latif
Energy-Communication Resilience
Research Group*



ENGINEERING
DEPARTMENT OF ELECTRICAL,
COMPUTER, AND SOFTWARE ENGINEERING